



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix: Drinking Water
Received: 06/15/21
Reported: 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-001	BHS-00-CR-IN-013-T	Classroom 013 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	30.4	5.00	µg/L	06/26/21	HI
424567-002	BHS-00-CR-IN-011-T	Classroom 011 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	9.67	5.00	µg/L	06/26/21	HI
424567-003	BHS-00-CR-IN-014-T	Classroom 014 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	29.9	5.00	µg/L	06/26/21	HI
424567-004	BHS-01-BT-IN-138G-	Girl's Restroom 138G Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	55.1	25.0	µg/L	06/26/21	HI
424567-005	BHS-01-T-IN-137-T	Official's Restroom 137					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	11.2	5.00	µg/L	06/26/21	HI
424567-006	BHS-01-STG--IN-180	Stage Chnging Rm 180 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	11.4	5.00	µg/L	06/26/21	HI
424567-007	BHS-01-GLR-IN-197-	Girl's Lcker Room 197 L					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	25.4	5.00	µg/L	06/26/21	HI
424567-008	BHS-01-GLR-IN-197-	Girl's Lcker Room 197 R					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	37.2	5.00	µg/L	06/26/21	HI
424567-009	BHS-01-NO-IN-175D-	Nurse's Exam Room D Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	22.8	5.00	µg/L	06/26/21	HI
424567-010	BHS-01-NO-IN-175C-	Nurse's Exam Room C Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	54.4	25.0	µg/L	06/26/21	HI
424567-011	GIN-01-T-IN-505-T	Restroom 505 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	27.6	5.00	µg/L	06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix: Drinking Water
Received: 06/15/21
Reported: 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-012	GIN-01-LIB-IN-316A-	Library 316A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-013	GIN-01-CR-IN-321-T	Classroom 321 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.32	5.00	µg/L	06/26/21	HI
424567-014	GIN-01-CR-IN-314-T	Classroom 314 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-015	GIN-01-CR-IN-308-T	Classroom 308 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	13.3	5.00	µg/L	06/26/21	HI
424567-016	OMS-01-CR-IN-037-T	Classroom 037 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.28	5.00	µg/L	06/26/21	HI
424567-017	OMS-01-CR-IN-047-T	Classroom 047 Sink 5					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-018	OMS-01-CR-IN-047-T	Classroom 047 Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.46	5.00	µg/L	06/26/21	HI
424567-019	OMS-01-CUS-IN-099-	Custodial Room 099 Mop					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.06	5.00	µg/L	06/26/21	HI
424567-020	OMS-01-CR-IN-007-T	Classroom 007 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-021	OMS-01-CR-IN-153-T	Classroom 153 R Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	36.5	5.00	µg/L	06/26/21	HI
424567-022	OMS-03-GO-IN-101C	Gym Office 101C Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	21.7	5.00	µg/L	06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix: Drinking Water
Received: 06/15/21
Reported: 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-023	OMS-03-GO-IN-101A	Gym Office 101A Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	41.7	10.0	µg/L	06/26/21	HI
424567-024	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	17.8	5.00	µg/L	06/26/21	HI
424567-025	FWH-01-RM-IN-130-	Room 130 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-026	FWH-01-HA-BY-162-	BF By Restroom 162					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-027	FWH-01-T-IN-162-T2	Restroom 162 R Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-028	TTC-01-GT-IN-25-T1	Girl's Restroom Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-029	TTC-01-GT-IN-25-T2	Girl's Restroom Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-030	TTC-01-GT-IN-25-T3	Girl's Restroom Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-031	TTC-01-BT-IN-27-T3	Boy's Restroom Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-032	TTC-01-BT-IN-27-T2	Boy's Restroom Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-033	TTC-01-BT-IN-27-T1	Boy's Restroom Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 424567

Matrix: Drinking Water
Received: 06/15/21
Reported: 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-034	CON-01-KIT-IN-CON-	Conc Mop Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-035	CON-01-KIT-IN-CON-	Conc Kitchen Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-036	CON-01-KIT-IN-CON-	Conc Kitchen Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-037	CON-01-KIT-IN-CON-	Conc Kitchen Sink 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-038	CON-01-EXT-BY-CO	Hose Bib By Bathrooms					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	19.7	5.00	µg/L	06/26/21	HI
424567-039	CON-01-EXT-BY-CO	Hose Bib By Serving					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	59.9	10.0	µg/L	06/26/21	HI
424567-040	CON-01-EXT-BY-CO	Field Hose Line East Side					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	24.2	5.00	µg/L	06/26/21	HI
424567-041	CON-01-EXT-BY-CO	Field Hose Line West Side					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	62.5	25.0	µg/L	06/26/21	HI
424567-042	OPS-01-KIT-IN-OPS-	Operations Kitchen Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-043	OPS-01-HA-IN-OPS-	Operations BF					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-044	OPS-01-SHP-IN-OPS	Operations Shop Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	424567
-----------------	--------

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-045	OPS-01-KIT-IN-OPS-	Operations Kitchen Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/29/21	SA
424567-046	MNT-01-KIT-IN-MNT-	Grounds Kitchen Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-047	MNT-01-HA-IN-MNT-	Grounds Drinking Fountain					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-048	MNT-01-KIT-IN-MNT-	Grounds Kitchen Coffee					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/29/21	SA
424567-049	BAR-01-T-IN-101C-T	Restroom 101C Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	14.8	5.00	µg/L	06/26/21	HI
424567-050	BAR-01-KIT-IN-106-T	Kitchen 106 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/26/21	HI
424567-051	BAR-01-EXT-BY-606-	Ext by Classroom 606 Hose					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	36.5	5.00	µg/L	06/26/21	HI
424567-052	BAR-01-CR-IN-120-T	Office 120 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	31.9	5.00	µg/L	06/26/21	HI
424567-053	BAR-01-T-IN-120-T	Office Restroom 120 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	54.6	10.0	µg/L	06/26/21	HI

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	424567
-----------------	--------

Matrix Drinking Water
Received 06/15/21
Reported 09/15/21

Attn:
Project: Brockport CSD LIW Testing
Location: 6.11.2021 Retest
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
424567-09/15/21 02:23 PM							

Reviewed By:

Approved Signatory

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 63556
Virginia	VELAP 11259

Report Amended. Edited sample -006 description per customer request

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.