



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 431414

Matrix: Drinking Water
Received: 08/02/21
Reported: 08/05/21

Attn:
Project: Brockport CSD Lead In Water
Location: 7.27.2021 Retest
Number: 2211782, Phase 2

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL*, Units, Analysis Date, Analyst. Contains 11 rows of lead analysis data for various locations like HS Nurses Exam Rm, HS Locker Rm, and Con Stand Field.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 431414

Matrix Drinking Water
Received 08/02/21
Reported 08/05/21

Attn:
Project: Brockport CSD Lead In Water
Location: 7.27.2021 Retest
Number: 2211782, Phase 2

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	15.8	5.00	µg/L	08/05/21	DLJ
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	08/05/21	DLJ

431414-08/05/21 04:30 PM

Jemil M. Lee
Reviewed By: _____
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 63556
Virginia	VELAP 11259

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
www.slabinc.com e-mail: info@slabinc.com

S 13

431414

V:431431414

tnadiem 8/2/2021 10:01:26 AM
UPS 1Z153E790358331039

Submitting Co. LaBella Associates, D.P.C. Lab WO# Phone (607) 591-7516
300 State Street Acct # 1126 Fax / Email cstamp@labellapc.com
Rochester, New York 14614 **State of Collection NY **Cert. Required Yes No
Project Name: Brockport CSD Lead in Water Testing Special Instructions [include requests for special reporting or data packages]
Project Location: 7.27.2021 Retest See attached spreadsheet
Project Number: 2211782, Phase 2
PO Number:

Turn Around Time Matrix / Sample Type (Select ONE) Tests / Analytes (Select ALL that Apply)
2 hours* Same day* 1 business day* 2 business day* 3 business days* 5 business days* Full TCLP (10d) Weekend*
Air Aqueous Bulk Hi-Vol Filter (PM10) Hi-Vol Filter (TSP) Oil Paint Sludge Soil
Solid Waste Wastewater Water, Drinking Compliance Wipe Wipe, Composite
Asbestos Air / Fiber Counts Asbestos Bulk / Asb ID Metals-Total Conc.
PCM (NIOSH 7400) TEM (AHERA) TEM (EPA Level II) PLM (EPA 600/R-93/116) PLM (EPA Point Count) PLM (Qualitative only) NYELAP 198.1/4/.6 CAELAP (EPA Interim) TEM (Chatfield)
Miscellaneous Tests Total Dust (NIOSH 0500) Resp. Dust (NIOSH 0600) Silica - FTIR (NIOSH 7602) Silica - XRD (NIOSH 7500) Mold Direct Exam
FOR ASBESTOS AIR: TYPE OF RESPIRATOR USED:
Metals-Extract TCLP / Lead TCLP / RCRA Metals TCLP / Full (w/ organics) Others

Table with columns: Sample #, Date Sampled, Time Sampled, Sample Identification, Wiped Area (ft²), pH / Temp, Time² (Start, Stop), Flow Rate³ (Start, Stop), Total⁴ Air.

¹Type: A=area B=blank P=personal E=excursion ²Beginning/End of Sample Period ³Pump Calibration in Liters/Minute ⁴Volume in Liters [time in min * flow in L/min]

Sampled by Cory Stamp Relinquished to lab by Cory Stamp
NAME SIGNATURE DATE/TIME 7/29/2021
Sample Disposal: Return to Sender (Shipping fees) Disposal by lab (\$50 fee)
Shipping Methods: FX HD UPS DB USM
WB:
Sample return requested Ambient temp Ice CI R S X Receive a physical copy of report.

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.

7.27.2021 Retest

Testing Order	New Identification Code	Description	Date Sampled	Time Sampled
1	HS Nurses Exam Room C	Nurse's Exam Room D Sink	7/27/2021	501
2	HS Nurses Exam Room D	Nurse's Exam Room C Sink	7/27/2021	501
3	HS Locker Room 129 Tap 1	Girl's Locker Room 129 Tap 1	7/27/2021	510
4	HS Locker Room 129 Tap 2	Girl's Locker Room 129 Tap 2	7/27/2021	510
5	HS Locker Room 129 Tap 3	Girl's Locker Room 129 Tap 3	7/27/2021	510
6	HS Locker Room 197 Left	Girl's Locker Room 197 Left Sink	7/27/2021	515
7	HS Locker Room 197 Right	Girl's Locker Room 197 Right Sink	7/27/2021	515
8	Con. Stand Field East	Field Hose Line, East Side	7/27/2021	525
9	Con. Stand Field West	Field Hose Line, West Side	7/27/2021	525
12	Con. South EXT HB	Hose Bib, South	7/27/2021	525
10	Con. Stand Ext. HB Bathrm	Hose Bib by Bathrooms	7/27/2021	535
11	Con. Stand Ext. HB Service	Hose Bib by Serving Window	7/27/2021	535
13	FHS Pot Filler 1	Kitchen 119 Pot Filler 1	7/27/2021	1305