



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	422328
-----------------	--------

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-001	FWH-01-T-IN-119-T	Kitchen Restrm 119 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-002	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	18.4	5.00	µg/L	06/07/21	JL
422328-003	FWH-01-KIT-IN-119-	Kitchen 119 Pot Filler 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.95	5.00	µg/L	06/07/21	JL
422328-004	FWH-01-KIT-IN-119-	Kitchen 119 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-005	FWH-01-KIT-IN-119-I	Kitchen 119 Ice Machine					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-006	FWH-01-KIT-IN-119-	Kitchen 119 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.23	5.00	µg/L	06/07/21	JL
422328-007	FWH-01-KIT-IN-119-	Kitchen 119 Sprayer					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-008	FWH-01-T-IN-108-T	Serving Area Restroom 108					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-009	FWH-01-SRV-IN-108-	Serving Area 108 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-010	FWH-01-CR-IN-109-T	Classrm 109 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-011	FWH-01-T-IN-109-T	Classrm Restrm 109					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-012	FWH-01-CR-IN-107-T	Classrm 107 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-013	FWH-01-CR-IN-106-T	Classrm 106 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-014	FWH-01-CR-IN-105-T	Classrm 105 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-015	FWH-01-CR-IN-104-T	Classrm 104 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-016	FWH-01-CR-IN-103-T	Classrm 103 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-017	FWH-01-CR-IN-102-T	Classrm 102 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-018	FWH-01-CR-IN-101-T	Classrm 101 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-019	FWH-01-CR-IN-100-T	Classrm 100 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-020	FWH-01-T-IN-123-T	Restrm 123 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-021	FWH-01-T-IN-125-T	Restrm 125 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-022	FWH-01-HA-BY-127-	Bottle Filler By Rm 127					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL*, Units, Analysis Date, Analyst. Rows include various sample IDs (e.g., 422328-023) and their corresponding analysis results for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-033	FWH-01-T-IN-164-T2	Restrm 164 Right Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-034	FWH-01-NO-IN-166-T	Nurse's Office 166 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-035	FWH-01-NO-IN-166B	Nurse's Office Exam Rm					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-036	FWH-01-T-IN-166C-T	Nurse's Office Restrm					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-037	FWH-01-NO-IN-168-T	Nurse's Office 168 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-038	FWH-01-T-IN-170-T	Classrm Restrm 170 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-039	FWH-01-CR-IN-171-T	Classrm 171 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.96	5.00	µg/L	06/07/21	JL
422328-040	FWH-01-CR-IN-174-T	Classrm 174 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-041	FWH-01-CR-IN-173-T	Classrm 173 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-042	FWH-01-CR-IN-176-T	Classrm 176 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-043	FWH-01-CR-IN-175-T	Classrm 175 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-044	FWH-01-CR-IN-178-T	Classrm 178 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-045	FWH-01-CR-IN-177-T	Classrm 177 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-046	FWH-01-CR-IN-180-T	Classrm 180 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-047	FWH-01-CR-IN-179-T	Classrm 179 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-048	FWH-02-T-IN-227-T	Library Restrm 227 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-049	FWH-02-T-IN-227B-T	Library 227B Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-050	FWH-02-HA-BY-223-	Bottle Filler By 223					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-051	FWH-02-FR-IN-223-T	Faculty Rm 223 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-052	FWH-02-CR-IN-213-T	Classrm 213 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.72	5.00	µg/L	06/07/21	JL
422328-053	FWH-02-CR-IN-211-T	Classrm 211 Sink 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-054	FWH-02-CR-IN-211-T	Classrm 311 Sink 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-055	FWH-02-CR-IN-208-T	Classrm 208 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-056	FWH-02-CR-IN-209-T	Classrm 209 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-057	FWH-02-CR-IN-206-T	Classrm 206 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-058	FWH-02-CR-IN-207-T	Classrm 207 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-059	FWH-02-CR-IN-204-T	Classrm 204 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-060	FWH-02-CR-IN-205-T	Classrm 205 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-061	FWH-02-CR-IN-202-T	Classrm 202 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-062	FWH-02-CR-IN-203-T	Classrm 203 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-063	FWH-02-CR-IN-200-T	Classrm 200 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-064	FWH-02-CR-IN-201-T	Classrm 201 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-065	FWH-02-T-IN-244-T	Classrm 244 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422328

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-066	FWH-02-T-IN-246-T	Classrm 246 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-067	FWH-02-CR-IN-271-T	Classrm 271 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-068	FWH-02-T-IN-270-T	Classrm 270 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-069	FWH-02-CR-IN-273-T	Classrm 273 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-070	FWH-02-CR-IN-274-T	Classrm 274 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-071	FWH-02-CR-IN-275-T	Classrm 275 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-072	FWH-02-CR-IN-276-T	Classrm 276 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-073	FWH-02-CR-IN-277-T	Classrm 277 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	6.11	5.00	µg/L	06/07/21	JL
422328-074	FWH-02-CR-IN-278-T	Classrm 278 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-075	FWH-02-CR-IN-279-T	Classrm 279 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL
422328-076	FWH-02-CR-IN-280-T	Classrm 280 Sink					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/07/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098


Order #: 422328

Matrix Drinking Water
Received 06/02/21
Reported 06/09/21

Attn:
Project: Brockport CSD Lead In Water
Location: Fred W Hill School
Number: 2211782

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422328-06/09/21 04:28 PM							


Reviewed By: _____
Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 63556
Virginia	VELAP 11259

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
www.slabinc.com e-mail: info@slabinc.com

S 76

422328

V:\422\422328
kdaniels 6/2/2021 9:45:54 AM
UPS 1Z153E79035679865

Submitting Co. LaBella Associates, D.P.C.	Lab WO#	Phone (607) 591-7516
300 State Street	Acct # 1126	Fax / Email cstamp@labellapc.com
Rochester, New York 14614	**State of Collection NY	**Cert. Required <input type="checkbox"/> Yes <input type="checkbox"/> No
Project Name: Brockport CSD Lead in Water Testing	Special Instructions [include requests for special reporting or data packages]	
Project Location: Fred W. Hill School	See attached spreadsheet	
Project Number: 2211782	Samples split between 2 boxes, copy of spreadsheet in each	
PO Number:		

Turn Around Time	Matrix / Sample Type (Select ONE)	Tests / Analytes (Select ALL that Apply)		
<input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day* <input type="checkbox"/> 1 business day* <input type="checkbox"/> 2 business day* <input type="checkbox"/> 3 business days* <input checked="" type="checkbox"/> 5 business days* <input type="checkbox"/> Full TCLP (10d) <input type="checkbox"/> Weekend* <small>* not available for all tests</small> <small>Schedule rush organics, multi-metals & weekend tests in advance.</small>	<small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input checked="" type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> <input type="checkbox"/> Soil <input type="checkbox"/>	Asbestos Air / Fiber Counts <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) <input type="checkbox"/> Miscellaneous Tests <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) <input type="checkbox"/> Mold Direct Exam	Asbestos Bulk / Asb ID <input type="checkbox"/> PLM (EPA 600/R-93/116) <input type="checkbox"/> PLM (EPA Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP 198.1/4/6 <input type="checkbox"/> CAELAP (EPA Interim) <input type="checkbox"/> TEM (Chatfield) <input type="checkbox"/> FOR ASBESTOS AIR: TYPE OF RESPIRATOR USED:	Metals-Total Conc. <input checked="" type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals <input type="checkbox"/> <input type="checkbox"/> Metals-Extract <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) Others: <input type="checkbox"/>

Sample #	Date Sampled**	Time Sampled**	Sample Identification (Employee, SSN, Bldg, Material, Type ¹)	Wiped Area (ft ²)	pH / Temp *	Time ²		Flow Rate ³		Total ⁴ Air
						Start	Stop	Start	Stop	
<i>See attached spreadsheet</i>										

¹Type: A=area B=blank P=personal E=excursion ²Beginning/End of Sample Period ³Pump Calibration in Liters/Minute ⁴Volume in Liters [time in min * flow in L/min]

Sampled by NAME <u>Cory Stamp</u> SIGNATURE <u>[Signature]</u> DATE/TIME <u>5/28/2021</u>	Relinquished to lab by NAME <u>Cory Stamp</u> SIGNATURE <u>[Signature]</u> DATE/TIME <u>5/28/2021</u>	Sample Disposal <small>If samples over req. weight (Refer to Fee Schedule)</small> <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee) Shipping Methods <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB:
---	---	--

Sample return requested Ambient temp Ice CI R S X Receive a physical copy of report.

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.

Fred W. Hill Elementary School

New Identification Code	Description	Time Sampled	Comments
FWH-01-T-IN-119-T	Kitchen Restroom 119 Sink	514	
FWH-01-KIT-IN-119-PF1	Kitchen 119 Pot Filler 1	514	
FWH-01-KIT-IN-119-PF2	Kitchen 119 Pot Filler 2	515	
FWH-01-KIT-IN-119-T1	Kitchen 119 Sink 1	516	
FWH-01-KIT-IN-119-IM	Kitchen 119 Ice Machine	517	
FWH-01-KIT-IN-119-T2	Kitchen 119 Sink 2	518	
FWH-01-KIT-IN-119-SP	Kitchen 119 Sprayer	519	
FWH-01-T-IN-108-T	Serving Area Restroom 108 Sink	521	
FWH-01-SRV-IN-108-T	Serving Area 108 Sink	522	
FWH-01-CR-IN-109-T	Classroom 109 Sink	530	
FWH-01-T-IN-109-T	Classroom Restroom 109 Sink	531	
FWH-01-CR-IN-107-T	Classroom 107 Sink	531	
FWH-01-CR-IN-106-T	Classroom 106 Sink	535	
FWH-01-CR-IN-105-T	Classroom 105 Sink	535	
FWH-01-CR-IN-104-T	Classroom 104 Sink	535	
FWH-01-CR-IN-103-T	Classroom 103 Sink	536	
FWH-01-CR-IN-102-T	Classroom 102 Sink	536	
FWH-01-CR-IN-101-T	Classroom 101 Sink	537	
FWH-01-CR-IN-100-T	Classroom 100 Sink	539	
FWH-01-T-IN-123-T	Restroom 123 Sink	539	
FWH-01-T-IN-125-T	Restroom 125 Sink	534	
FWH-01-HA-BY-127-BF	Bottle Filler by Room 127	534	
FWH-01-T-IN-130A-T	Restroom 130A Sink	535	
FWH-01-RM-IN-130-T	Room 130 Sink	539	
FWH-01-RM-IN-130-CT	Room 130 Coffee Line	539	
FWH-01-LR-IN-133-T	Locker Room 133 Sink	539	
FWH-01-LR-IN-135-T	Locker Room 135 Sink	541	
FWH-01-T-IN-150-T	Office Restroom 150 Sink	541	
FWH-01-HA-BY-162-BF	Bottle Filler by Restroom 162	544	
FWH-01-T-IN-162-T2	Restroom 162 Right Sink	546	
FWH-01-T-IN-164-T1	Restroom 164 Left Sink	546	
FWH-01-T-IN-162-T1	Restroom 162 Left Sink	546	
FWH-01-T-IN-164-T2	Restroom 164 Right Sink	547	
FWH-01-NO-IN-166-T	Nurse's Office 166 Sink	548	
FWH-01-NO-IN-166B-T	Nurse's Office Exam Room 166B Sink	549	
FWH-01-T-IN-166C-T	Nurse's Office Restroom 166C Sink	550	
FWH-01-NO-IN-168-T	Nurse's Office 168 Sink	550	
FWH-01-T-IN-170-T	Classroom Restroom 170 Sink	551	
FWH-01-CR-IN-171-T	Classroom 171 Sink	552	
FWH-01-CR-IN-174-T	Classroom 174 Sink	552	
FWH-01-CR-IN-173-T	Classroom 173 Sink	553	
FWH-01-CR-IN-176-T	Classroom 176 Sink	553	
FWH-01-CR-IN-175-T	Classroom 175 Sink	554	
FWH-01-CR-IN-178-T	Classroom 178 Sink	554	
FWH-01-CR-IN-177-T	Classroom 177 Sink	554	

FWH-01-CR-IN-180-T	Classroom 180 Sink	555	
FWH-01-CR-IN-179-T	Classroom 179 Sink	556	
FWH-02-T-IN-227-T	Library Restroom 227 Sink	559	
FWH-02-T-IN-227B-T	Library 227B Sink	559	
FWH-02-HA-BY-223-BF	Bottle Filler by 223	601	
FWH-02-FR-IN-223-T	Faculty Room 223 Sink	602	
FWH-02-CR-IN-213-T2	Classroom 213 Sink 2	603	
FWH-02-CR-IN-211-T1	Classroom 211 Sink 1	604	
FWH-02-CR-IN-211-T2	Classroom 311 Sink 2	604	
FWH-02-CR-IN-208-T	Classroom 208 Sink	604	
FWH-02-CR-IN-209-T	Classroom 209 Sink	605	
FWH-02-CR-IN-206-T	Classroom 206 Sink	605	
FWH-02-CR-IN-207-T	Classroom 207 Sink	606	
FWH-02-CR-IN-204-T	Classroom 204 Sink	607	
FWH-02-CR-IN-205-T	Classroom 205 Sink	608	
FWH-02-CR-IN-202-T	Classroom 202 Sink	608	
FWH-02-CR-IN-203-T	Classroom 203 Sink	609	
FWH-02-CR-IN-200-T	Classroom 200 Sink	609	
FWH-02-CR-IN-201-T	Classroom 201 Sink	610	
FWH-02-T-IN-244-T	Classroom 244 Sink	610	
FWH-02-T-IN-246-T	Classroom 246 Sink	611	
FWH-02-CR-IN-271-T	Classroom 271 Sink	612	
FWH-02-T-IN-270-T	Classroom 270 Sink	613	
FWH-02-CR-IN-273-T	Classroom 273 Sink	614	
FWH-02-CR-IN-274-T	Classroom 274 Sink	615	
FWH-02-CR-IN-275-T	Classroom 275 Sink	616	
FWH-02-CR-IN-276-T	Classroom 276 Sink	617	
FWH-02-CR-IN-277-T	Classroom 277 Sink	617	
FWH-02-CR-IN-278-T	Classroom 278 Sink	618	
FWH-02-CR-IN-279-T	Classroom 279 Sink	618	
FWH-02-CR-IN-280-T	Classroom 280 Sink	619	