



**Customer:** Labella Associates (1126)  
**Address:** 300 State Street  
Rochester, NY 14614-1098

**Order #:** 422290

**Matrix** Drinking Water  
**Received** 06/02/21  
**Reported** 06/09/21

**Attn:**  
**Project:** Brockport CSD LIW Testing  
**Location:** Oliver Middle School  
**Number:** 2211782

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
422290-001	01-CO-IN-030A-T	Custodian's Office 030A					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-002	01-CR-IN-033-T	Classroom 033 Utility					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	5.98	5.00	µg/L	06/04/21	JL
422290-003	01-CR-IN-035-T	Classroom 035 Utility					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-004	01-CR-IN-037-T	Classroom 037 Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422290-005	01-CR-IN-047-T7	Classroom 047 Sink 7					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	7.14	5.00	µg/L	06/04/21	JL
422290-006	01-CR-IN-047-T6	Classroom 047 Sink 6					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	7.04	5.00	µg/L	06/04/21	JL
422290-007	01-CR-IN-047-T1	Classroom 047 Sink 1					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	6.96	5.00	µg/L	06/04/21	JL
422290-008	01-CR-IN-047-T5	Classroom 047 Sink 5					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							
422290-009	01-CR-IN-047-T2	Classroom 047 Sink 2					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
422290-010	01-CR-IN-047-T4	Classroom 047 Sink 4					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2					
Sample not received.							

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Parameter, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 21 rows of lead analysis data for various locations like Classroom 047 Sink, Classroom 048 Sink, Bottle Filler By Restroom, etc.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains multiple rows for different samples and their analysis results.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



**Customer:** Labella Associates (1126)  
**Address:** 300 State Street  
Rochester, NY 14614-1098

<b>Order #:</b>	422290
-----------------	--------

**Matrix** Drinking Water  
**Received** 06/02/21  
**Reported** 06/09/21

**Attn:**  
**Project:** Brockport CSD LIW Testing  
**Location:** Oliver Middle School  
**Number:** 2211782

**PO Number:**

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
<b>422290-032</b>	02-CR-IN-153-T1	Classroom 153 Left Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-033</b>	02-CR-IN-153-T2	Classroom 153 Right Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	28.5	5.00	µg/L	06/04/21	JL
<b>422290-034</b>	02-FAC-IN-150-T	Faculty Room 150 Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-035</b>	02-FAC-IN-150-CT	Faculty Room 150 Coffee					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<10.0	10.0	µg/L	06/08/21	JL
<b>422290-036</b>	03-HA-BY-127-BF	BF By Restroom 127					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-037</b>	03-NO-IN-112-T	Nurse's Office 112 Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-038</b>	03-T-IN-112-T	Nurse's Office 112					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-039</b>	03-GO-IN-101C-T	Gym Office 101C Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	18.1	5.00	µg/L	06/04/21	JL
<b>422290-040</b>	03-GO-IN-101A-T	Gym Office 101A Sink					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	41.5	10.0	µg/L	06/05/21	JL
<b>422290-041</b>	04-HA-BY-260-BF	BF By Faculty Room 260					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL
<b>422290-042</b>	05-HA-BY-227-BF	BF By Restroom 227					
<b>Metals Analysis</b>							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	06/04/21	JL

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 422290

Matrix: Drinking Water
Received: 06/02/21
Reported: 06/09/21

Attn:
Project: Brockport CSD LIW Testing
Location: Oliver Middle School
Number: 2211782

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL\*, Units, Analysis Date, Analyst. Contains 4 rows of Metals Analysis for Lead.

422290-06/09/21 04:47 PM

Reviewed By: [Signature]
Analyst

EPA Regulatory Limits

Table with 3 columns: Parameter, Reg. Limit, Unit. Row: Lead, 15.0, µg/L

State Certifications

Table with 4 columns: Method, Parameter, New York, Virginia. Includes rows for ELAP and VELAP certifications for Lead.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and \*Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



# SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117  
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475  
www.slabinc.com e-mail: info@slabinc.com

S 46

## 422290

V:422\422290

6/2/2021 9:45:54 AM

1Z153E790357338043

Submitting Co. <b>LaBella Associates, D.P.C.</b>	Lab WO#	Phone (609) fghraizi	UPS
<b>300 State Street</b>	Acct # <b>1126</b>	Fax / Email <b>cstamp@labellapc.com</b>	
<b>Rochester, New York 14614</b>	**State of Collection <b>NY</b>	**Cert. Required	<input type="checkbox"/> Yes <input type="checkbox"/> No
Project Name: <b>Brockport CSD Lead in Water Testing</b>	Special Instructions [include requests for special reporting or data packages]		
Project Location: <b>Oliver Middle School</b>	<b>See attached spreadsheet</b>		
Project Number: <b>2211782</b>			
PO Number:			

Turn Around Time	Matrix / Sample Type (Select ONE)	Tests / Analytes (Select ALL that Apply)		
<input type="checkbox"/> 2 hours* <input type="checkbox"/> Same day* <input type="checkbox"/> 1 business day* <input type="checkbox"/> 2 business day* <input type="checkbox"/> 3 business days* <input checked="" type="checkbox"/> 5 business days* <input type="checkbox"/> Full TCLP (10d) <input type="checkbox"/> Weekend* <small>* not available for all tests</small> <small>Schedule rush organics, multi-metals &amp; weekend tests in advance.</small>	<small>All samples on form should be of SAME matrix type. Use additional forms as needed.</small> <input type="checkbox"/> Air <input type="checkbox"/> Solid <input type="checkbox"/> Aqueous <input type="checkbox"/> Waste <input type="checkbox"/> Bulk <input type="checkbox"/> Wastewater <input type="checkbox"/> Hi-Vol Filter (PM10) <input checked="" type="checkbox"/> Water, Drinking <input type="checkbox"/> Hi-Vol Filter (TSP) <input type="checkbox"/> Compliance <input type="checkbox"/> Oil <input type="checkbox"/> Wipe <input type="checkbox"/> Paint <input type="checkbox"/> Wipe, Composite <input type="checkbox"/> Sludge <input type="checkbox"/> _____ <input type="checkbox"/> Soil <input type="checkbox"/> _____	<b>Asbestos Air / Fiber Counts</b> <input type="checkbox"/> PCM (NIOSH 7400) <input type="checkbox"/> TEM (AHERA) <input type="checkbox"/> TEM (EPA Level II) <input type="checkbox"/> _____ <b>Miscellaneous Tests</b> <input type="checkbox"/> Total Dust (NIOSH 0500) <input type="checkbox"/> Resp. Dust (NIOSH 0600) <input type="checkbox"/> Silica - FTIR (NIOSH 7602) <input type="checkbox"/> Silica - XRD (NIOSH 7500) <input type="checkbox"/> Mold Direct Exam	<b>Asbestos Bulk / Asb ID</b> <input type="checkbox"/> PLM (EPA 600/R-93/116) <input type="checkbox"/> PLM (EPA Point Count) <input type="checkbox"/> PLM (Qualitative only) <input type="checkbox"/> NYELAP 198.11.4/6 <input type="checkbox"/> CAELAP (EPA Interim) <input type="checkbox"/> TEM (Chatfield) <input type="checkbox"/> _____ <b>FOR ASBESTOS AIR:</b> TYPE OF RESPIRATOR USED: _____	<b>Metals-Total Conc.</b> <input checked="" type="checkbox"/> Lead <input type="checkbox"/> RCRA Metals <input type="checkbox"/> _____ <input type="checkbox"/> _____ <b>Metals-Extract</b> <input type="checkbox"/> TCLP / Lead <input type="checkbox"/> TCLP / RCRA Metals <input type="checkbox"/> TCLP / Full (w/ organics) <b>Others</b> <input type="checkbox"/> _____

Sample #	Date Sampled**	Time Sampled**	Sample Identification (Employee, SSN, Bldg, Material, Type <sup>1</sup> )	Wiped Area (ft <sup>2</sup> )	pH / Temp *	Time <sup>2</sup>		Flow Rate <sup>3</sup>		Total <sup>4</sup> Air
						Start	Stop	Start	Stop	
<p>See attached spreadsheet</p>										

<sup>1</sup>Type: A=area B=blank P=personal E=excursion <sup>2</sup>Beginning/End of Sample Period <sup>3</sup>Pump Calibration in Liters/Minute <sup>4</sup>Volume in Liters [time in min \* flow in L/min]

<b>Sampled by</b> NAME <u>Cory Stamp</u> SIGNATURE <u>[Signature]</u> DATE/TIME <u>5/27/2021</u>	<b>Relinquished to lab by</b> NAME <u>Cory Stamp</u> SIGNATURE <u>[Signature]</u> DATE/TIME <u>5/28/2021</u>	<b>Sample Disposal</b> <small>If samples over req. weight (Refer to Fee Schedule)</small> <input type="checkbox"/> Return to Sender (Shipping fees) <input type="checkbox"/> Disposal by lab (\$50 fee) <b>Shipping Methods</b> <input type="checkbox"/> FX <input type="checkbox"/> UPS <input type="checkbox"/> USM <input type="checkbox"/> HD <input type="checkbox"/> DB WB: _____
---	---	--

Sample return requested  Ambient temp  Ice  Cl  R  S  X  Receive a physical copy of report.

\* Temperature taken with IR Gun A. \*\*Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.

Oliver Middle School			
Identification Code	Description	Time Sampled	Comments
OMS-01-CO-IN-030A-T	Custodian's Office Restroom 030A	514	
OMS-01-CR-IN-033-T	Classroom 033 Utility Sink	515	
OMS-01-CR-IN-035-T	Classroom 035 Utility Sink	516	
OMS-01-CR-IN-037-T	Classroom 037 Sink	516	
OMS-01-CR-IN-047-T7	Classroom 047 Sink 7	517	
OMS-01-CR-IN-047-T6	Classroom 047 Sink 6	517	
OMS-01-CR-IN-047-T1	Classroom 047 Sink 1	517	
OMS-01-CR-IN-047-T5	Classroom 047 Sink 5	518	
OMS-01-CR-IN-047-T2	Classroom 047 Sink 2	518	
OMS-01-CR-IN-047-T4	Classroom 047 Sink 4	518	
OMS-01-CR-IN-047-T3	Classroom 047 Sink 3	519	
OMS-01-CR-IN-048-T	Classroom 48 Sink	521	
OMS-01-HA-BY-044-BF	Bottle Filler by Restroom 044	524	
OMS-01-KIT-IN-069-T1	Kitchen 069 Prep Sink 1	525	
OMS-01-KIT-IN-069-PF1	Kitchen 069 Pot Filler 1	525	
OMS-01-KIT-IN-069-PF2	Kitchen 069 Pot Filler 2	525	
OMS-01-KIT-IN-069-PF3	Kitchen 069 Pot Filler 3	525	
OMS-01-KIT-IN-069-T2	Kitchen 069 Prep Sink 2	526	
OMS-01-KIT-IN-069-T3	Kitchen 069 Prep Sink 3	526	
OMS-01-KIT-IN-069-IM	Kitchen 069 Ice Machine	527	
OMS-01-FSO-IN-062-T	FSO 062 Sink	527	
OMS-01-GO-IN-082-T	Gym Office 082 Restroom Sink	529	
OMS-01-CON-IN-084-T	Concessions 084 Sink	532	
OMS-01-HA-BY-089-BF	Bottle Filler by Weight Room 089	533	
OMS-01-CUS-IN-099-MS	Custodial Room 099 Mop Sink	535	
OMS-01-CUS-IN-099-IM	Custodial Room 099 Ice Machine	537	SPLIT INTO 3 BOTTLES
OMS-01-CR-IN-007-T	Classroom 007 Sink	539	
OMS-02-MUS-IN-128-T	Band Room 128 Sink	542	
OMS-03-MT-IN-116-T	Auditorium 116 Men's Toilet	543	
OMS-03-WT-IN-116-T	Auditorium 116 Women's Toilet	543	
OMS-02-HA-BY-160-BF	Bottle Filler by Room 160	545	
OMS-02-CR-IN-153-T1	Classroom 153 Left Sink	546	
OMS-02-CR-IN-153-T2	Classroom 153 Right Sink	546	
OMS-02-FAC-IN-150-T	Faculty Room 150 Sink	547	
OMS-02-FAC-IN-150-CT	Faculty Room 150 Coffee Line	548	
OMS-03-HA-BY-127-BF	Bottle Filler by Restroom 127	550	
OMS-03-NO-IN-112-T	Nurse's Office 112 Sink	551	
OMS-03-T-IN-112-T	Nurse's Office 112 Restroom Sink	551	
OMS-03-GO-IN-101C-T	Gym Office 101C Sink	543	
OMS-03-GO-IN-101A-T	Gym Office 101A Sink	544	
OMS-04-HA-BY-260-BF	Bottle Filler by Faculty Room 260	550	
OMS-05-HA-BY-227-BF	Bottle Filler by Restroom 227	552	
OMS-05-FAC-IN-221-T	Faculty Room 221 Sink	554	
OMS-05-FAC-IN-221-CT	Faculty Room 221 Coffee Line	559	
OMS-05-LIB-IN-228-T	Library Room 228 Sink	600	

OMS-06-HA-BY-327-BF

Bottle Filler by Restroom 327

601